

Customer:	Internal	kW Rating:	230kW	Date:	5/7/2020
Address:	5123 Hiltonview Rd. Houston, TX 77086	Model:	XQ230	Technician:	
Contact:		Serial Number:	X3R01172	Job #:	2202

Time	Load %	kW	A	Amps B	C	A-B	Volts A-C	B-C	Hz	Oil Pressure	Water Temp.	Ambient Temp.
9:30AM	58	134	160	160	161	480	480	479	60	68	171	39
9:45AM	58	134	160	161	160	480	480	479	60	65	190	39
10:00AM	81	185	224	222	224	480	479	480	60	52	194	39
10:15AM	95	219	262	259	274	477	474	474	60	46	205	39
10:30AM	95	219	262	259	274	477	474	474	60	44	212	39

COMMENTS: 15 Minutes @ 50% Load; 15 Minutes @ 75% Load; 30 Minutes @ 100% Load
 If load requirements are not achievable due to load bank steps, load unit as close to the load requirement as possible. Record in notes section below.