

Customer:	Internal	kW Rating:	230kW	Date:	5/19/2020
Address:	5123 Hiltonview Rd. Houston, TX 77086	Model:	XQ230	Technician:	
Contact:		Serial Number:	X3R00136	Job #:	2203

Time	Load %	kW	Amps			Volts			Hz	Oil Pressure	Water Temp.	Ambient Temp.
			A	B	C	A-B	A-C	B-C				
12:00PM	2	4	5	5	5	480	480	480	60	102	90	
12:15PM	22	52	62	62	62	480	480	480	60	61	178	
12:30PM	65	150	180	180	180	480	480	480	60	52	187	
12:45PM	87	200	240	240	240	480	480	480	60	49	189	
1:00PM	107	247	297	296	297	480	480	480	60	48	190	
1:15PM	87	200	240	240	240	480	480	480	60	51	187	
1:30PM	87	200	240	240	240	480	480	480	60	50	189	
1:45PM	87	200	240	240	240	480	480	480	60	50	189	
2:00PM	87	200	240	240	240	480	480	480	60	50	189	

COMMENTS: 15 Minutes @ 50% Load; 15 Minutes @ 75% Load; 30 Minutes @ 100% Load
 If load requirements are not achievable due to load bank steps, load unit as close to the load requirement as possible. Record in notes section below.