



Customer:		kW Rating:	116	Date:	10-1-21
Address:	5123 Hiltonview Rd. Houston, TX 77086	Model:	HR5W145	Technician:	Victor
Contact:		Serial Number:	V11400499	Job/Item #:	2529

Time	Load %	kW	Amps			Volts			Hz	Oil Pressure	Water Temp.	Ambient Temp.
			A	B	C	A-B	A-C	B-C				
9:00	0	0	0	0	0	479	480	480	60	63	140	76
9:15	54%	63	76	76	76	478	480	480	60	60	192	76
9:30	77%	89	107	107	108	478	479	480	60	54	195	76
9:45	95%	110	132	133	134	479	480	481	60	51	199	76
10:00	95%	110	132	133	133	479	479	480	60	50	203	76

COMMENTS: 15 Minutes @ 50% Load; 15 Minutes @ 75% Load; 30 Minutes @ 100% Load
 If load requirements are not achievable due to load bank steps, load unit as close to the load requirement as possible. Record in notes section below.