



Customer:		kW Rating:	116	Date:	10-28-21
Address:	5123 Hiltonview Rd. Houston, TX 77086	Model:	HRJW145	Technician:	Victor
Contact:		Serial Number:	U11400496	Job/Item #:	2533

Time	Load %	kW	Amps			Volts			Hz	Oil Pressure	Water Temp.	Ambient Temp.
			A	B	C	A-B	A-C	B-C				
3:55	0	0	0	0	0	478	480	480	60	60	167	76
4:10	47%	55	69	68	67	479	480	480	60	52	192	76
4:25	73%	85	102	102	101	478	479	480	60	49	194	76
4:40	98%	114	140	139	138	479	480	479	60	46	206	76
4:55	98%	113	138	138	137	478	480	481	60	45	208	76

COMMENTS: 15 Minutes @ 50% Load; 15 Minutes @ 75% Load; 30 Minutes @ 100% Load  
 If load requirements are not achievable due to load bank steps, load unit as close to the load requirement as possible. Record in notes section below.